

Service and Application Notes

Date 6/26/76

File No. MT-7612

Subject CB10 Coil/Blower Cooling Application

When the CB10 is used for a cooling only application, a field installed transformer is required for the 24 volt control circuit.

The transformer can be installed in the blower assembly. Use a P-8-5744 foot-mounted transformer. This is a 230/24 volt, 30VA transformer.

COOLING

LENNOX Industries Inc.