

Service and Application Notes

Date 1/1/77

File No. MT-7701

Subject HP8 HEAT PUMP WITH CB11 BLOWER COIL

The CB11 blower coil can be used in a heat pump application with an HP8 outdoor unit. Special consideration must be taken in selecting the matching components. The correct match is as follows:

<u>Heat Pump</u>	<u>Blower Coil</u>
HP8-211	CB11-26
HP8-261	CB11-41
HP8-311	CB11-41

Do not attempt to apply the CB11-21 with the HP8-211 or the CB11-26 with the HP8-261. This will result in unacceptably high head pressures.

HEAT PUMP